

R O Z B O R

C.odb.miesta : 012 312318 0001 Cislo rozboru : 94/141
Okres : Cis.zakazky : 0
Druh objektu : Dat/hod odberu : 01.03.94/ 0.00
Objekt : Odobral :
Lokalita : Sucha Dolina
Typ odb.miesta : vodojem
Odberatel :
Naz.odb.miesta : Sucha Dolina vodojem

Kod--U-K-A-Z-O-V-A-T-E-L-----Spina-normu---Vysledok

1	fek.koli bakter v 100 ml	757111	0
2	koli bakter.v 100 ml	757111 ne	1
3	enterokoky v 100 ml	757111	0
4	mezo bakterie v 1 ml	757111	12
5	psychro.bakt. v 1 ml	757111	33
6	mikroorg.zive v 1 ml	757111	0
7	mikroorg.mrtve v 1ml	757111	0
8	bezb.bicikovci v 1ml	757111	0
9	abioseston (%)	757111	1.5
12	dusichany (mg/l)	757111	11.85
26	chloridy (mg/l)	757111	21.27
27	chut	757111	0
29	rozp.latky (mg/l)	757111	412
30	mangan (mg/l)	757111	0
32	pach	757111	0
33	pH reakce vody	757111	7.90
38	vapnik a horcik (mmol/l)	757111	3.65
39	zakal (ZFT)	757111	0
41	zelezo (mg/l)	757111	0
42	amonne ionty (mg/l)	757111	0
44	dusitany (mg/l)	757111	0.05
45	horcik (mg/l)	757111	20.67
46	chem.spot.kysl.manganist.mg/l	757111	0.4
48	aktivny chlor (mg/l)	757111 ne	0
50	kys.neutr.kap.do pH=4,5mmol/l	757111	4.7
51	vapnik (mg/l)	757111	110.22
52	spec.vodivost (mS/m)	757111	57.81

Veduci laboratoria : Ing.Krajnakova Iveta

Pocet ukazovatelov nesplnajucich normu : 2
Celkovy pocet kvalitativnych ukazovatelov : 27

H O D N O T E N I E R O Z B O R U

Vysetrovana vzorka vody v stanovenych ukazovateloch nevyhovuje
CSN 75 7111.

R O Z B O R

C.odb.miesta : 012 312319 0002 Cislo rozboru : 94/140
Okres : Cis.zakazky : 1
Druh objektu : Dat/hod odberu : 01.03.94/ 0.00
Objekt : Odobral :
Lokalita : Sucha Dolina
Typ odb.miesta : rozvod. siet
Odberateľ :
Naz.odb.miesta : Sucha Dolina

Kod--U-K-A-Z-O-V-A-T-E-L-----Splna-normu---Vysledok

1	fek.koli bakter v 100 ml	757111	0
2	koli bakter.v 100 ml	757111 ne	1
3	enterokoky v 100 ml	757111 ne	2
4	mezo bakterie v 1 ml	757111 ne	35
5	psychro.bakt. v 1 ml	757111	47
6	mikroorg.zive v 1 ml	757111	0
7	mikroorg.mrtve v 1ml	757111	0
8	bezb.bicikovci v 1ml	757111	0
9	abioseston (%)	757111	1.5
12	dusicnany (mg/l)	757111	14.18
26	chloridy (mg/l)	757111	26.59
27	chut	757111	0
29	rozp.latky (mg/l)	757111	382
30	mangan (mg/l)	757111	0
32	pach	757111	0
33	pH reakce vody	757111	7.90
38	vapnik a horcik (mmol/l)	757111	3.35
39	zakal (ZFT)	757111	0
41	zelezo (mg/l)	757111	0
42	amonne ionty (mg/l)	757111	0
44	dusitany (mg/l)	757111	0.01
45	horcik (mg/l)	757111	21.89
16	chem.spot.kysl.manganist.mg/l	757111	0.56
48	aktivny chlor (mg/l)	757111 ne	0
50	kys.neutr.kap.do pH=4,5mmol/l	757111	5.5
51	vapnik (mg/l)	757111	98.2
52	spec.vodivost (mS/m)	757111	51.46

Veduci laboratoria : Ing.Krajnakova Iveta

Pocet ukazovatelov nesplnajucich normu : 4
Celkovy pocet kvalitativnych ukazovatelov : 27

H O D N O T E N I E R O Z B O R U

Vysetrovana vzorka vody v stanovenych ukazovateloch nevyhovuje
CSN 75 7111.

Východoslovenské
VODÁRNE A KANALIZÁCIE
štátny podnik Košice
z á v o d
081 51 P R E Š O V
15